WIFI Digital Heating ThermostatUser Manual

Many thanks for your selection of our products and services, and also for your trust and support to us.

Search for "Smart life" from google play or App store to Download the Wifi App



Turn on the thermostat, press and hold the

Activate WIFI distribution network icon

Features

- Includingbuilt-in sensor and external sensor
- 0.5°C accuracy keeps temperature within the level you set.
- Children lockto prevent misoperation by children
- Data memory when power is off.
- Holiday mode make you enjoy more comfortable temperature in holiday
- The temperature of external sensor can be checked


Product Specifications

☆ Power: 90-240Vac 50/60Hz ☆Range of temperature display:: 1~70°C

☆Display accuracy:: 0.5°C☆Insulating condition: Normal environment ☆ Probe sensor:: NTC(10k)1%☆ Running program: Set per 1 week as a cycle ☆Contact capacity:: 3A/(WW);16A/(WE) ☆Output: Switch relay ☆ Limit temperature range:: 1~70°C☆Installation: recessed type (in the wall)

☆Range of temperature adjustment:: 5~35°C ☆Size(mm): 86*86*27

Wiring Diagram



Electric heating wiring diagram Water heating wiring diagram

(do not connect terminal "close 4" of electric valve)

AC90-240V 50/60Hz Water heating and gas wall-hung boiler heating, nocontact wiringdiagram, (disconnection when electric valve close)

Note: 5&6 connect with gas boiler ,3&4 connect with N and L line . If normally closed thermal actuator ,then connect with 2&3,if normally open thermal actuator .then connect with 1&3

Displays



Description of icon

Auto mode;run preset program Manual mode

Programming mode

Temporary manual mode

f Holiday mode, Holiday days and temperature can be set to run in countdown mode

* Heating,, icon disappears to stop heating

EXT External NTC sensor

F WIFI connection, flashing EZ distribution mode

Child lock

Wifi status: Disconnection

Cloud icon: flashing AP distribution network mode

Activate window function

Room temp

SET Setting temp

Cooling mode, the icon blinking means cooling mode output

Operation key

-	ution key	T					
NO	symbols	represent					
A	(0)	Turn ON/OFF:Short press to turn on/ turn off					
В	,	1 Short press 🏄 to switch automatic mode and manual mode					
	₹© ₽	2 Turn on thermostat, long press for 3-5 seconds to enter into programmable					
		setting					
		3.Turn off thermostat, long press ♣2 for 3-5 seconds to enter into advancedoption A					
С	4—4	1 Confirm key: use it with 🏂 key					
"		2 Only short pressit to set time					
	_0	3 Turn on thermostat,long press it for 3-5seconds to holiday mode setting. Appear					
		OFF , press igotimes or igotimes change to ON,then press igotimes to confirm opening holiday mode					
		4 Turn off thermostat ,long press it for 3-5s to enter into advanced option B					

D		1 Decrease key 2 Long press to lock /unlock
Е	Æ	1 Increase key; 2 Long press to inquire external sensor temperature (only available for BN item select N3 in the advance option B) 3 In the program model, press ♥ or ♠enter to temporary manual mode
F	∱ ≊ •	Press them together to enter matching wifi mode

Programmable

5+2 (factory default),6+1 and 7 models 6 times period setting for user choose. In the advanced options choose model of you need, under power on state, long press for 3-5 seconds enter into programming mode setting, then short press choose: hour,minute, time period, and press and to adjust data, finished setting, about 10 seconds will automatic save and exist.

			•		•		•				Ŀ
Wake up		Leave	home	Back h	ome	Leave	home	Back h	ome	Sleep	
6: 00	20℃	8: 00	15℃	11: 30	15℃	13:30	15℃	17:00	15℃	22:00	15℃

The optimum comfort temperature is $18^{\circ}\text{C}-22^{\circ}\text{C}$.

Advanced option A

Power off state, long press for 3-5 seconds to access advanced option A.

From A1 to AF, short press $^{$60$}$ to choose the option, and adjust data by $^{\mbox{$70$}}$ or $^{\mbox{$40$}}$, short press $^{\mbox{$40$}}$ to switch next option. Remain about 5 seconds after finish setting will quit setting.

NO	Setting Options	Data Setting Function	Factory Default
A1	Measure Temperature Calibration	-1	
A2	Start/stop working temperature difference setting	1 ℃	
А3	Children lock setting	0:half lock 1:full lock	0
A4	Power on/off state memory after electricity cut	0:Thermostat on/off with memory whenel ectrify 1:Thermostat off when electrify 2:Thermostat on when electrify	0
A5	Standby bright	0: Off 1: Weakly bright 2: Brighter	10
A6	Logo display on standby 0: No display 1: Display		
А7	Weekly programming selection	0: 5+2 1: 6+1 2: 7	0

A8	Setting temperature minimum limit	1-10°C	5°C
А9	Setting temperature maximum limit	20-70°C	35°C
AA	Low temperature protection	1-10°C When setting temp = 10 °C, if press \triangleq will display $\{\}$, cancel low temperature protection	5°C
АВ	High temperature protection for external sensor	20°C-70°C When setting temp =20°C, , if press ♥ will display 【 】 , cancel high temperature protection	45°C
AC	High temperature protection temperature difference setting	1-9°C	2°C
AD	Window function triggers temperature	10-20°C,setting temperature is 10°C,decrease it ,will display 【】,then canceled this function	
AE	Window function running time	10-20min	10
AF	Restore factory defaults Display Ao , long press 👼 key to whole show		
АН	Heating/Cooling mode	0: heating 1: cooling	0

Advanced option B

Power off state, long press for 3-5 seconds to access advanced option B.

short press $^{\text{los}}$ to choose the option, and adjust data by ∇ or \triangle , short press $^{\text{los}}$ to switch next option. Remain about 5 seconds after finish setting will guit setting.

NO	Setting Options	Data Setting Function	Factory Default
BN	Options of sensor control	N1:Internal sensor (high temperature protection close) N2:External sensor (high temperature protection close) N3:Internal sensor control temperature ,external sensor limit temperature (external sensor detect the temperature is higher than highest temperature of external sensor, thermostat will Close relay,turn off load)	N1
ВС	Descaling function	0: Disable descaling function 1: Enable descaling function	0
Во	product information	Can't be changed	

Return difference: limit valve of external sensor is 45°C for factory default (A6),value of external sensor control return difference (A3) is 2. when temperature rise to 45°C, then relay stop working and will remind high temperature production alarm. If temperature decline to 43°C relay continue to work and

heating alarm will be relieved. (it can be operated ,only when room temperature is lower than setting temperature)

Sensor fault display:please choose correct working way of built-in and external sensor, if choose wrongly or sensor fault (breakdown), "E1" or "E2" will be displayed on the screen. Thermostat will stop heatinguntil the fault is eliminated

Installation diagram:

